

Fire suppression systems intended for use in engine compartments with combustion engines

Issued to**BlazeCut s.r.o.**

Triblavinská 3191, SK-900 25 Chorvátsky Grob, Slovakia

Manufacturing site

same as above

Product and product name

BlazeCut Automatic Fire Suppression System, for details, see page 2.

Classification

Test scenario rating	Level of openness	Class A fire
B	3	A

Technical data/Performance

See appendix to this certificate.

Certificate

The product described in this certificate fulfils the requirements in RISE Certification rules regarding Fire suppression systems intended for use in engine compartments with combustion engines, SPCR 199:2021. The certification is based on the manufacturer's technical file and type tests performed in accordance with standards specified in the appendix to this certificate.

Marking

Marking shall show SPCR 199, RISE logo, manufacturer's logo, the number of this certificate, the name of the product, its serial number, the name of the manufacturer and RISE P-symbol. See last page in this certificate for details.

Validity

This certificate is valid until no longer than 2029-02-15. The validity of this certificate can be verified at RISE homepage. This edition of the certificate replaces previous editions.

Miscellaneous

The manufacturer's in-house inspection is under surveillance by RISE in accordance with section 4 and 5 of SPCR 199:2021. Other terms and conditions are set out in section 6 of SPCR 199:2021.



Martin Tillander

Certificate C901028 | issue 2 | 2024-02-25

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

☎ +46 10 516 50 00 | certifiering@ri.se | www.ri.se

1232755

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

Page 1 (4)

Product information**Technical data of the tested suppression system**

Table 1 shows technical data of the suppression system tested for 4 m³ engine compartment volumes. The system may be scaled to fit the size of a specific engine compartment according to the scaling rules in SP Method 4912.

Table 1, technical data of the tested fire suppression system

Suppression agent	BlazeCut ABC Powder
Suppression agent volume and mass	Volume of cylinder 13 L, amount of suppression agent 10 kg
Propellant gas	Nitrogen
Mass of propellant gas	130 g
Working pressure	25 bar – operating pressure at 20°C
Suppression agent delivery hose	Red fire hose, ½", inner diameter 13 mm. Red fire hose, ¼", inner diameter 6mm
Suppression agent delivery pipes	Stainless steel pipe OD/ID = 12/10 mm
Total length of agent delivery system	20 m, 10 m per outlet
Number of nozzles	6 pcs
Type of nozzles	3 x ANP120, 2 x ANP160, 1 x ANP360
Distance to the most remote nozzle	9.3 m
Fittings, amount of each type	Straight coupling 12 pcs 90° elbow 9 pcs 45° elbow 1 pc T-coupling 4 pcs
Thermal cycling resistance	ISO 16750-3:2012
Mechanical stress resistance (vibration and shock)	ISO 16750-3:2012 (Test VII)
Corrosion resistance	ISO 21207:2022, test method B (3 cycles)

Product performance

Performance rating according to SP Method 4912

Table 2, Fire scenario

Rating	Description	Ventilation (m ³ /s)	Result
A +	Low fire load	3	
	High fire load	3	
	Hidden fire	3	
A	Hidden fire	1.5	
B	Hidden fire	0	Pass
C	Low fire load	3	
	High fire load	3	
D	Low fire load	0	Pass*
E	High fire load	0	Pass
	High fire load	1,5	Pass
	Low fire load	1.5	Pass
	Re-ignition >300s	0	Pass (no re-ignition)

*Passed with the mass of extinguishing agent reduced to 83% of the nominal mass.

Table 3, level of openness

Level	Criteria
1	Fire tests passed with open mockup
2	Fire tests passed without mockup floor and ceiling
3	Fire tests passed without mockup floor
4	Fire tests passed with all sides closed on mockup

Table 4, class A fire

Description	Ventilation (m ³ /s)	Remarks
Class A fire	0.5	Extinguished within 60 s after activation of the suppression system. No re-ignition.
Pass		

Conditions

Electrical equipment included in the system shall have a classification of at least IP65, and be tested in accordance with ISO 20653:2013.

A risk assessment in accordance with SPCR 199:2021 section 3.2 shall be made prior to equipment being placed into service. The risk assessment shall be made by personnel having documented experience for the task.

It is the responsibility of the suppression system manufacturer to assure compliance of its suppression system components with legal requirements and vehicle manufacturer requirements.

The marking of the product shall be legible and durable and be designed as below, size 40x60 mm. It shall be applied in conjunction to the engine compartment.

Marking plate:

