Annex to the EU – Type Examination Certificate no. 01066/5/2025-CERT-01

Range of approval

Type of valve:	ILP and DLP
Maximum allowable pressure PS:	30.0 bar (ILP), 25.0 bar (DLP)
Test pressure PT:	42.0 bar (ILP), 30.0 bar (DLP)
Volume V:	1.0 – 65.0 L
Extinguishing agent:	foam, antifreeze foam, fluorine-free foam, powder, FK-5-1-12, HFC-227ea, HFC-236fa, water
Propellant gas:	nitrogen (N_2) (group 2 according to the Directive 2014/68/EU)

Pressure equipment	Volume / DN	PS	PT	TS max/min	Fluid group	Category	Module	EU Certificate number
Vessel	1 – 65 L	30 bar	43 bar	-30/60°C	2	III	H	CE-1697-PED-H-VAL043-24-LVA
Vessel	1 – 65 L	20 bar	30 bar	-30/60°C	2	III	H	CE-1697-PED-H-VAL043-24-LVA
Valve ILP	DN 30	35 bar	42 bar	-40/65°C	2	SEP	Type approval*	01069/5/2025-CERT-01
Valve DLP	DN 30	25 bar	30 bar	-40/65°C	2	SEP	Type approval*	01069/5/2025-CERT-02

*Type approval according to the Directive 2010/35/EU

TECHNICKÁ INŠPEKCIA NB 1354 -5- SLOVENSKÁ REPUBLIKA

JUDr. Vladimír Jurík
General Director