

Certificate of Product Approval

Certificate Number: 1765a

Issue: 01

BlazeCut s.r.o.

Triblavinská 3191
90025 Chorvátsky Grob
Slovakia

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Direct low pressure (DLP) application fixed fire suppression system

(Refer to attached appendix for details)

Standards

LPS 1666: Issue 1.0

Requirements and test procedures for the LPCB approval of direct low pressure (DLP) application fixed fire suppression systems, using heat sensitive pneumatic detection tubing, for the protection of small defined volume unoccupied enclosures.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Louise Jackman

Verifier

11 September 2023

Date of Issue

11 September 2023

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1765a BlazeCut s.r.o.

Issue: 01

BlazeCut C Series DLP system

Product Name	Size	Description	Detector tube	Cylinder valve	Natural ventilation	Forced ventilation	LPCB Ref. No
LPCB CFK 116 0.9	0.9 kg	0.9 kg FK-5-1-12 DLP system	BlazeTube O/D 6 mm	116	Enclosed and open options ⁵	Forced and natural ⁶	1765a/01
LPCB CFK 116 1.8	1.8 kg	1.8 kg FK-5-1-12 DLP system	BlazeTube O/D 6 mm	116	Enclosed and open options ⁵	Forced and natural ⁶	1765a/02
LPCB CFK 116 3.75	3.75 kg	3.75 kg FK-5-1-12 DLP system	BlazeTube O/D 6 mm	116	Enclosed and open options ⁵	Forced and natural ⁶	1765a/03
LPCB CFK 118 0.9	0.9 kg	0.9 kg FK-5-1-12 DLP system	BlazeTube O/D 8 mm	118	Enclosed and open options ⁵	Forced and natural ⁶	1765a/04
LPCB CFK 118 1.8	1.8 kg	1.8 kg FK-5-1-12 DLP system	BlazeTube O/D 8 mm	118	Enclosed and open options ⁵	Forced and natural ⁶	1765a/05
LPCB CFK 118 3.75	3.75 kg	3.75 kg FK-5-1-12 DLP system	BlazeTube O/D 8 mm	118	Enclosed and open options ⁵	Forced and natural ⁶	1765a/06
LPCB CFK 126 1.8	1.8 kg	1.8 kg FK-5-1-12 DLP system	BlazeTube O/D 6 mm	126	Enclosed and open options ⁵	Forced and natural ⁶	1765a/07
LPCB CFK 126 3.75	3.75 kg	3.75 kg FK-5-1-12 DLP system	BlazeTube O/D 6 mm	126	Enclosed and open options ⁵	Forced and natural ⁶	1765a/08
LPCB CFK 128 1.8	1.8 kg	1.8 kg FK-5-1-12 DLP system	BlazeTube O/D 8 mm	128	Enclosed and open options ⁵	Forced and natural ⁶	1765a/09
LPCB CFK 128 3.75	3.75 kg	3.75 kg FK-5-1-12 DLP system	BlazeTube O/D 8 mm	128	Enclosed and open options ⁵	Forced and natural ⁶	1765a/10

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Louise Jackman

Verifier

11 September 2023

Date of Issue

11 September 2023

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1765a BlazeCut s.r.o.

Issue: 01

Notes:

1. BlazeCut DLP Systems shall be configured, installed, serviced and maintained in accordance with BlazeCut "C Series Direct Clean Agent Systems Manual DLPCAM2307-EU DLP LPCB Clean agents Manual.
2. These systems are intended solely to provide enhanced local fire protection. They are not intended for use as whole room or building fire protection systems.
3. These systems use a single method for detection and delivery of the extinguishing agent to the activation point.
4. System operating pressure 15 bar. System operating temperature range -20°C to +60°C.
5. Installed systems may have natural air vents at high or low level (see note 1).
6. Installed systems may have forced ventilation (see note 1).

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Louise Jackman
Verifier

11 September 2023
Date of Issue

11 September 2023
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre