



Technická inšpekcia, a.s.

Trnavská cesta 56, 821 01 Bratislava, Slovenská republika

CERTIFICATE

No. 629/1/2023

**Technická inšpekcia, a. s. according to the STN EN ISO/IEC 17020,
issues this certificate on the safety of technical equipment**

Date of assessment: 27.01.2023, 28.02.2023

Name of equipment: BlazeCut Automatic Fire Suppression System

Type: T Series

Model designation: T xxx E S B -E and T xxx FK S B -E
(Descriptions in annex to the Certificate)

Manufacturer: BlazeCut s.r.o, Triblavinská 3191, 900 25 Chorvátsky
Grob, Slovak Republic

Applicant: BlazeCut s.r.o, Triblavinská 3191, 900 25 Chorvátsky Grob,
Slovak Republic

Plant: BlazeCut s.r.o, Triblavinská 3191, 900 25 Chorvátsky Grob,
Slovak Republic

Documents for issuing a certificate: Inspection Report No. 629/1/2023

After conducting the inspection and based on the facts found Technická inšpekcia, a. s.

confirms that:

The device meets the basic safety requirements of technical devices verified by the test.

Bratislava, 28th February 2023



CERT11-056

Technická inšpekcia, a.s.

Ing. Jozef Kamzík

Director of the Regional office - Bratislava



A 005954

ANNEX TO CERTIFICATE No.: 629/1/2023

The Certificate covers all T Series models under the below designation.

Model designation: T xxx E S B -E and T xxx FK S B -E

Caption Explanation:

Product line

T – Tube Series systems

Approximate tube length

xxx – three-digit number for tube length designation

Range: 250 – 6000 mm (025 – 600)

Extinguishing agent used

E – HFC-227ea

FK – FK-5-1-12

Pressure monitoring component

S – pressure switch

NOTE: If a pressure switch is not installed this caption will be absent.

Packaging

B – bulk

NOTE: If a product is supplied in retail packaging, this caption will be absent.

Economy pressure switch

E – economical pressure switch

NOTE: If an economical pressure switch is not installed this caption will be absent.

Technická inšpekcia, a.s.

Ing. Jozef Kamzík

Director of the Regional office - Bratislava



CERT11-056

